

The World Spa Apartment Owners Association


Sector -30&41 Gurugram

BOQ for Replacement & Servicing of Swimming Pool Filters and Other Accessories

S.No	Description	UOM	Qty	Rate of Supply	Rate Of erection	Remarks
1	Supply, Installation & testing of Swimming pools Centrifugal Pump 2HP Single phase port size 63mm, Capacity 28,800 Ltr/Hr Brand :- Lyxar/ willo/ Halbert with required fittings,hardware's.	Nos	3			
2	Supply, Installation & testing of 2 Inch side mount multiport valve brand- ACL material :- ABS with required fittings,	Nos	4			
3	Complete supply, Installation & testing of Swimming Pool Vortex / willo/ halbert equivalent air blower model number : LVB800 power :- 3 HP three phase	Nos	1			
4	Supply, Installation & testing of NRV 2" as installed Make :- ERA/HARIT/Zloto/ shant Equivalent with required hardware's.	Nos	3			
5	Supply, Installation & testing of PVC Ball valve with fittings, hardware's & bends 2inch ERA/HARIT/ Prince Equivalent, Schedule -80.	Nos	2			
6	Supply, Installation & testing of PVC Ball Valve 3inch ERA/HARIT/Prince Equivalent , schedule 80	Nos	1			
7	Supply, Installation & testing of Side Mounted multi port valve sand filter :- filter type : sand filter, material : Mild Steel Brand Lyxar, Hayward, Jandy / Equivalent Valve size 2inch Capacity 30000LPH tank diameter 900mm with required fittings are hardware's	Nos	1			
8	Supply, Installation & testing of Pump Cap as installed, Make: Hayward equivalent	Nos	1			
9	Supply, Installation & testing of Sand Media : Material : stone packing 50Kg.	Kg	1500			
10	Dismantling of Installed fittings and accessories	Job	1			
		Sub Total				
		GST 18%				
		Grand Total				


Udairaj Singh
Technical Manager

Email Approval
Ved Prakash
Manager Technical


Harpreet Singh
Estate Head

Email Approval
19-3-2026
Authorized BOM
TWSAOA